



NOTES:

1. SEE IRRIGATION SPECIFICATIONS FOR BACKFILLING AND COMPACTION REQUIREMENTS.
2. SEE IRRIGATION SPECIFICATIONS FOR MINIMUM BACKFILL DEPTHS FROM FINISH GRADE.
3. INSTALL 24-VOLT CONTROL WIRING ADJACENT TO PRESSURE MAIN LINE, MAXIMUM 3-INCHES ABOVE AND AT SIDE OF MAIN LINE.
4. PROVIDE EXPANSION LOOP IN WIRE BUNDLES AT ALL CHANGES IN DIRECTION (45°, 90° CORNERS ETC.)
5. PVC PIPE SHALL NOT BE BENT INSIDE TRENCH TO A POINT WHERE THERE IS STRESS ON GLUED FITTINGS.
6. NO STACKING OF PIPES ALLOWED, OR MORE THAN THREE PIPES IN CONJOINED TRENCHES.