



NOTES:

- ① GAS RISER (ANODELESS RISER ON PLASTIC SERVICE LINES)
- ② SHUT-OFF VALVE (LUBRICATED PLUG VALVE)
- ③ DIELECTRIC UNION
- ④ TEST PORT (1/4" NPT VALVE WITH PLUG)
- ⑤ FILTER
- ⑥ REGULATOR (REFER TO DIVISION 33 FOR SPECIFICATION)
- ⑦ METER (REFER TO DIVISION 33 FOR SPECIFICATION)
- ⑧ SEISMIC SHUT-OFF VALVE (REFER TO DIVISION 33 FOR SPECIFICATION)
- ⑨ TYPICAL METER ASSEMBLY SUPPORTS
- ⑩ FLEX
- ⑪ 3/4" SCHEDULE 40 PVC CONDUIT TO BUILDING FOR REMOTE MONITORING. CONNECT GAS METER TO MAIN BUILDING ELECTRICAL METER WITH BELDEN 5302F1 18-4 WIRE PER STANDARD DETAIL, BUILDING ELECTRICAL METER & UTILITY METER DIAGRAM.
- ⑫ MASK AND PAINT ENTIRE ASSEMBLY EXCEPT METER, REGULATOR, AND SEISMIC VALVE.